
SECTION A
SCALE: 3/8"=1'-0"
SECTION B
SCALE: 3/8"=1'-0"
ELEVATION E-1
SCALE: 3/8"=1'-0"
ELEVATION E-2
SCALE: 3/8"=1'-0"
ELEVATION E-3
SCALE: 3/8"=1'-0"
SEE CONTINUATION
SHEET METAL THERMOCOUPLE JUNCTION BOX 12" x 12" x 6" DEEP WITH SCREEN ATTACHED COVER
DOOR B-1
DOOR B-2
SHEET METAL ENCLOSURE 36" WIDE x 90" HIGH x 30" DEEP WITH HINGED FRONT DOORS & FRONT LATCH
VIEWING WINDOW
HINGE
J-BOX FOR VIEWING WINDOW LIGHTS FOR MOUNTING REFER TO DETAIL
SHEET METAL ENCLOSURE 36" WIDE x 90" HIGH x 30" DEEP WITH HINGED FRONT DOOR & 3 POINT LATCH
J-BOX FOR VIEWING WINDOW LITE FOR MOUNTING REFER TO DETAIL FOR PENDULUM MIXING SEE ELEVATION E-2 SHEET 21 #4
NOTES:
1 FOR SCHEDULE OF SEALABLE JUNCTION BOXES "SJB" SEE DRAWING E-2.11.
2 FOR LIGHTING FIXTURE SCHEDULE, GENERAL NOTES, LIST OF SYMBOLS AND ABBREVIATIONS SEE E-2.11 & E-2.2
HALF SIZE PRINT
SNAP - 1 FACILITY, SANTA SUSANA, CALIFORNIA
PHASE IV
U.S. ATOMIC ENERGY COMMISSION
CHICAGO OPERATIONS OFFICE
ENVIRONMENTAL TEST BUILDING
VAULT SECTIONS &
ELEVATIONS
ELECTRICAL
ISSUED FOR CLIENT APPROVAL