

COOLING TOWER POWER PLAN
SCALE: 1/8"=1'-0"


480V RESONATING HORN, FEDERAL MODEL 31 OR EQUAL (47-67)
TELEPHONE TERMINAL CABINET (SEE DETAIL SH. # E-12)
AMPLIFIER (SPACE ONLY)
(30V VIBRATORY PANEL) FEDERAL MODEL 30A OR EQUAL (45-45C)
LIGHTING PANEL "LA"
RECEPTACLE FOR AMPLIFIER
LA-23
LA-93
TO LTG. PANEL "LA"
TO TEL. TERM. CAB.
TO RM. MONITOR PANEL
TERMINAL CABINET #3 SEE DETAIL SH. # E-12
TERMINAL CABINET #4 SEE DETAIL SH. # E-12
TERMINAL CABINET #2 SEE DETAIL SH. # E-12
TERMINAL CABINET #1 SEE DETAIL SH. # E-12
TO BMS
TO TEL. TERM. CAB.
TO RM. 118 TEL. TERM. CAB.
TO RM. 118 TEL. TERM. CAB. IN RM. 118
TO RM. 118 TEL. TERM. CAB. IN RM. 118
TO RM. 118 TEL. TERM. CAB. IN RM. 118