

PLAN
SCALE: ½"=1'-0"

ELEVATION
SCALE: ½"=1'-0"

NOTE: PRE-COMPRESSION DIMENSIONS SHALL BE ⅛" LESS THAN FILTER CHANGER DIMENSIONS.

PRE-COMPRESSION FIXTURE
SCALE: 3"=1'-0"



SECTION ②
SCALE: 3"=1'-0"



SECTION ①
SCALE: 3"=1'-0"



RECEIVER BOX.



FILTER DATA
NOT TO SCALE



COVER PLATE ①

SEAL DETAIL ②
NOT TO SCALE



TYPICAL DUCT CONN. DETAIL ③
SCALE: 3"=1'-0"

FILTER RECEIVER
SCALE: 3"=1'-0"

SPECIAL NOTES:-
1. ALL SHIELDING MATERIAL SHALL BE LEAD IN STEEL PLATE ENCLOSURE EXCEPT AS OTHERWISE NOTED.
2. ALL STEEL WELDED CONSTRUCTION EXCEPT AS OTHERWISE NOTED.

FOR GENERAL NOTES SEE DWG. 7756.

LEGEND
LEAD SHIELDING - REMOVABLE SHIELD POT
LEAD SHIELD - FILTER CHANGER.

HALF SIZE PRINT

A	ISSUED FOR CLIENT APPROVAL	8-1-58
	REVISIONS	

APPROVED 8-26-58
U.S. ATOMIC ENERGY COMMISSION

SNAP-II FACILITY, SANTA SUSANA, CALIFORNIA
PHASE II
U.S. ATOMIC ENERGY COMMISSION
CHICAGO OPERATIONS OFFICE

ENVIRONMENTAL TEST BUILDING
SHIELDED FILTER CHANGER
INFILTRATION AIR SYSTEM
MECHANICAL SPECIALTIES

DES.	S.P.
DRN.	W.A.
CHK.	
SCALE	AS NOTED
DATE	8-1-58

THIS DRAWING IS PREPARED UNDER THE SUPERVISION OF A REGISTERED ENGINEER

DWG. NO. 7757
REV. A
SHEET 1