

**Outfall 200 Mercury Treatment Facility
Request for Proposal 89303318REM000002
Questions and Answers Round 3 - Questions 20 to 23
Posted April 16, 2018**

No.	Industry Question	DOE Answer
20.	<p>Will the 3D BIM Model be provided in a format other than PDF (i.e. .nwd, .dxf, ...)?</p> <p>The file format provided is not viewable in 3D BIM Model viewers. Providing the model in a viewable format would greatly assist in clarifying portions of the project and allow the contractor to assess the Level of Detail (100-500) already in the model.</p>	<p>No, the 3D model files are provided for illustrative purposes only.</p>
21.	<p>RFP Section L – Attachment L-10 <i>Assumptions</i> We are assuming craft labor man hours for System Acceptance Testing (SAT) are correct to the site jurisdiction. Specifically regarding the use of laborers for the majority of SAT.</p>	<p>The detailed procedures for System Acceptance Testing are not yet developed, therefore DOE has not contacted the local labor union to verify that these labor categories are correct to the site jurisdiction.</p> <p>Note that Offerors are to consider and use all assumptions in Attachment L-10 <i>Assumptions</i> for proposal preparation.</p>
22.	<p>Spec 40 27 00 Process Piping Please confirm that leak detection for dual contained piping is manual inspection only via leak detection ports/valves. (i.e. electrical leak detection is not required.)</p>	<p>Yes, per Attachment J-1 <i>Specifications</i>, Sections 40 27 00.15A, B, and C, only visual inspection via manual drain fittings is required.</p>
23.	<p>Will the Government please publish the site visit attendee list?</p>	<p>The Pre-Proposal Site Tour Registration List was posted to the <i>Pre-Proposal Site Tour</i> tab of the procurement website on 4/11/2018.</p>