

NOTES:

1. MAXIMUM LOAD RATING FOR LIFTING EYE: 2000 LBS.
2. SUBMIT DATA ON EYE BOLT WITH SHOP DRAWINGS.

TYPE 1



NOTES:

1. MAXIMUM LOAD RATING FOR LIFTING EYE 4000 LBS.
2. SUBMIT DATA ON EYE BOLT WITH SHOP DRAWINGS.

TYPE 2

LIFTING EYE

NTS

0512-121

ALUMINUM		
NOMINAL BEAM DEPTH, INCHES	ROWS OF BOLTS	LENGTH OF ANGLE
10	3	7 1/2"
7-8-9	2	5"
5-6	1	3"
4	1	2 3/4"

NOTES:

1. NUMBER OF ROWS IS EQUAL TO NUMBER OF BOLTS TO ENCLOSED WEB.
2. ALL FRAMING CONNECTIONS SHALL CONFORM TO SCHEDULE UNLESS DETAILED OTHERWISE ON FRAMING PLANS.



NOTE:

✳ 2 1/2" DIMENSION TYPICAL EXCEPT 2" FOR 4" BEAM.

0514-020



NOTES:

1. 2 1/2" DIMENSION TYPICAL EXCEPT 2" FOR 4" BEAMS.
2. DO NOT CUT EXISTING CONCRETE BEAM TOP REINFORCEMENT DURING DRILL-IN ANCHOR INSTALLATION. FIELD LOCATE BEAM REINFORCEMENT PRIOR TO FABRICATION. ADD LENGTH TO CLIP ANGLES AS REQUIRED TO LOWER ANCHORS TO CLEAR REINFORCEMENT WHILE MAINTAINING SPACING AND EDGE DISTANCE AS SHOWN.
3. WHERE BOTH ENDS OF BEAM ARE ATTACHED TO A WALL, PROVIDE LONG HORIZONTALLY SLOTTED HOLES IN BEAM WEB AT ONE END. TIGHTEN NUTS SNUG TIGHT, BACK OFF 1/2 TURN, AND LOCK WITH DOUBLE NUT.

0514-056



DECKING LEDGER SUPPORT ANGLE

NTS

0531-001



OPENING	CLOSURE
2'-0" < W ≤ 4'-0"	L 3x3x1/4
4'-0" < W ≤ 6'-0"	L 4x3x1/4 (LLV)
6'-0" < W	NA

DECK SPAN	SUPPORT
L ≤ 6'-0"	L 4x3x1/4 (LLV)
6'-0" < L ≤ 7'-6"	L 5x3x1/4 (LLV)
7'-6" < L	NA

OPENINGS 2'-1" TO 6'-0"





OPENINGS 1'-0" TO 2'-0"

NOTES:

1. ATTACH METAL DECKING TO ALL SUPPORTS PERPENDICULAR TO DECKING SPAN WITH SPECIFIED FASTENERS AT EACH VALLEY OF DECKING. ATTACH METAL DECKING TO SUPPORTS PARALLEL TO SPAN @ 6" ON CENTER. WHERE VALLEY OF DECKING DOES NOT FALL AT SUPPORTS PARALLEL TO DECK SPAN, PROVIDE FILLER PIECES FOR EQUAL ATTACHMENTS.
2. REFER TO SPECIFICATIONS FOR SMALLER DECK OPENING REINFORCEMENT.

ROOF DECK OPENING

NTS

0531-021



NOTES:

1. TOTAL NUMBERS OF STUD SHEAR CONNECTORS PER BEAM SHOWN ON FRAMING PLANS BY [X]. SPACE STUDS UNIFORMLY OVER FULL LENGTH OF BEAM.
2. FOR SLAB AND DECKING DEPTH, SEE PLANS.

COMPOSITE BEAM

NTS

0536-005

NOTES:

1. PROVIDE PROTECTION FOR DISSIMILAR METALS AND CONCRETE AS SPECIFIED.
2. AMERICAN STANDARD C12x7.41 ALUMINUM STRINGERS TYPICAL EXCEPT WHERE OTHERWISE NOTED ON PLANS.
3. STAIR HANDRAIL NOT SHOWN.
4. STAIR MANUFACTURER TO COORDINATE BOLTED TREADS AND HANDRAIL CONNECTIONS.
5. ALL FASTENERS SHALL BE STAINLESS STEEL.
6. FIELD VERIFY DIMENSIONS AND ELEVATIONS PRIOR TO FABRICATION.
7. FOR RISER PLATE SEE PARTIAL RISER PLATE DETAIL UNLESS NOTED OTHERWISE. CLEARANCE BETWEEN TOP OF RISER PLATE AND BOTTOM OF TREAD TO BE 3 3/4" MAX. FOR STAIRS WITH PICKET HANDRAIL EXTEND RISER PLATE PER FULL RISER PLATE DETAIL.







STAIR DETAILS - ALUMINUM

NTS

DETAIL 1 OF 2

0551-001

| | | |