

**SECTION J – LIST OF DOCUMENTS, EXHIBITS AND OTHER ATTACHMENTS**

**ATTACHMENT J-8.C.3.5.3.2.12 Portable Fire Extinguisher Listing**

**SECTION J-LIST OF DOCUMENTS, EXHIBITS AND OTHER ATTACHMENTS**

**ATTACHMENT J-8.C.3.5.3.2.12 Portable Fire Extinguisher Listing**

Extinguisher Type	Size	Quantity
Dry Chemical	5 lb.	2,403
Dry Chemical	10 lb.	4
Dry Chemical	20 lb.	264
CO2	15 lb.	11
CO2	20 lb.	81
CO2	50 lb.	72
Total		2,835

Extinguisher Type	Inspection/Test	Frequency	Maintenance Required	Location
All	Visual	Monthly	None	On-site
Carbon Dioxide (CO2)	Weight	Annual	Reweigh & conductivity	On-site
Carbon Dioxide (CO2)	Hydrostatic (HST)	5 Years	HST Test and refill	Off-site
Dry Chemical	Recharge	6 Years	Dump, rebuild head, refill, and recharge	On-site
Dry Chemical	Hydrostatic (HST)	12 Years	HST Test and refill	Off-site HST On-site refill

Note: Testing and maintenance of fire protection systems (e.g., sprinkler systems, fire alarms, smoke detection systems, smoke/heat vents, etc.), semi-annual sprinkler tests, and monthly fire inspections for life safety conditions remains the responsibility of the Deactivation contractor.